



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 090704-R13162A

ISSUE DATE: July 9, 2004

Page 1 of 1

Issued to: Intumex GmbH
Buchnerplatz 1
A-4021 Linz, AUSTRIA

Report Reference: R13162


This is to Certify that representative samples of: Fill, Void or Cavity Material designated as Intumex MG Caulk

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 1479, Fire Tests of Through-Penetration Firestops.

Additional Information: Intumex MG Caulk is intended to be used as a Fill, Void or Cavity Material in Through-Penetration Firestop System Nos. C-AJ-1455, C-AJ-2410, C-AJ-2411, C-AJ-2412, C-AJ-2413, C-AJ-2414, C-AJ-5232, F-C-1102, F-C-2258, F-C-2259, W-L-2336, W-L-2337.

Only those products bearing the UL Classification Marking should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Marking includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

LOOK FOR THE UL CLASSIFICATION MARKING ON THE PRODUCT

Engineer:
Alec Hauser
Underwriters Laboratories Inc.

Review Engineer:
Steven J. Hoffman
Underwriters Laboratories Inc.



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 090704-R13163

ISSUE DATE: July 9, 2004

Page 1 of 1

Issued to: Intumex GmbH
Buchnerplatz 1
A-4021 Linz, AUSTRIA

Report Reference: R13163


**This is to Certify that
representative samples of:** Firestop Device designated as Intumex UniCollar

**Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated
on this Certificate.**

Standard(s) for Safety: ANSI/UL 1479, Fire Tests of Through-Penetration Firestops.

Additional Information: Intumex UniCollar is intended to be used as a Firestop Device in Through-Penetration Firestop System Nos. C-AJ-2330, C-AJ-2370, C-AJ-2410, C-AJ-2411, F-A-2124, F-C-2258, F-C-2259, W-L-2270, W-L-2336, W-L-2337.

**Only those products bearing the UL Classification Marking should be considered as being
covered by UL's Classification and Follow-Up Service.**

The UL Classification Marking includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

LOOK FOR THE UL CLASSIFICATION MARKING ON THE PRODUCT

Engineer:
Alec Hauser
Underwriters Laboratories Inc.



Review Engineer:
Steven J. Hoffman
Underwriters Laboratories Inc.

